



# ENV AUTOMATION PTE LTD

60 Paya Lebar Road, #07-54 Paya Lebar Square, Singapore 409051  
Email: envautomation.sg@gmail.com | Website: www.autosiltstopper.com

CERTIFICATE NO  
**ENV2026010**

## CALIBRATION CERTIFICATE

This certificate confirms that the instrument listed below has been inspected and calibrated according to internal inspection requirements and applicable calibration practice.

<b>CLIENT INFORMATION</b>	
Samsung C&T Corporation	
<b>PROJECT NAME</b>	
CR112	
<b>SENSOR TYPE</b>	<b>SENSOR NUMBER</b>
TSS Sensor	864650056139590
<b>DATE OF CALIBRATION</b>	<b>NEXT CALIBRATION</b>
11/09/2025	11/09/2026 <span>VALID</span>

Test Items	Test Requirements	Test Result
Visual inspection test	No obvious scratches, damage, ect	<span>Qualified</span>
Does the screw have a leak lock	There is no	<span>Qualified</span>
There is no sundry in the sensor	There is no	<span>Qualified</span>
There is no sundry in the sensor	Soak for more than 12 hours without water	<span>Qualified</span>
There is no sundry in the sensor	Connect the transmitter OK	<span>Qualified</span>
There is no sundry in the sensor	High temperature test for 3 hours the above	<span>Qualified</span>
There is no sundry in the sensor	Oscillate 250 rpm for more than 2 hours	<span>Qualified</span>

Functional Test	Standard Solution		Actual Measurement	
Calibration test (mg / L : 10 % 10 mg /L) (Standard)	Solution 1	0.2	0.53	0.33
	Solution 2	207	204.97	1.0 %
	Solution 3	5070	5012.49	1.1 %
	Solution 4	12050	12237.36	1.6 %

Note : Before testing must refer to the customer requirement and inspection standards.

AUTHORIZED BY



Checked by Signature

OFFICIAL COMPANY STAMP

